



# Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

Governor Asa Hutchinson

Nathaniel Smith, MD, MPH, Director and State Health Officer

Engineering Section, Slot 37

[www.Healthy.Arkansas.gov/eng/](http://www.Healthy.Arkansas.gov/eng/)

Ph 501-661-2623

After Hours Emergency 501-661-2136

Fax 501-661-2032

Monday, October 31, 2016

LEMLEY, AMBER  
LITTLE RIVER CO RDA  
P. O. BOX 527  
FOREMAN, AR 71836


RE: BOIL WATER NOTICE LIFT  
LITTLE RIVER CO RDA - PWS ID # 787  
LITTLE RIVER COUNTY

Dear Manager:

The Department of Health has released the "Boil Water" Notice confirmed on 10/27/2016 8:59:56 AM by Brandon Walraven for the all connections north of the inetersection of HWY 41 & HWY 32, including Arkinda. This order was issued as a precautionary measure because of the possibility that contaminated water may have entered the distribution system as a result of complete loss in normal system pressure.

Bacteriological samples taken on Monday, October 31, 2016 were found to be free of bacterial contamination and a satisfactory disinfectant level has been established throughout the distribution system. The water is therefore considered "Safe" for human consumption and the "Boil Water" notice is hereby lifted.

Sincerely,

  
Jason Gilkey  
Environmental Health Specialist  
Engineering Section

**LITTLE RIVER CO RDA  
LITTLE RIVER COUNTY**

**PRECAUTIONARY BOIL ORDER NOTICE**

LIFT DATE: MONDAY, OCTOBER 31, 2016

FOR FURTHER INFORMATION, CONTACT  
JASON GILKEY  
ENVIRONMENTAL HEALTH SPECIALIST  
ENGINEERING SECTION, (501) 661-2623

NEWS ARTICLE

FOR IMMEDIATE RELEASE

THE DEPARTMENT OF HEALTH HAS RELEASED THE "BOIL WATER" NOTICE ISSUED ON 10/27/2016 8:59:56 AM BY BRANDON WALRAVEN FOR THE ALL CONNECTIONS NORTH OF THE INETERSECTION OF HWY 41 & HWY 32, INCLUDING ARKINDA. THIS ORDER WAS ISSUED AS A PRECAUTIONARY MEASURE BECAUSE OF THE POSSIBILITY THAT CONTAMINATED WATER MAY HAVE ENTERED THE DISTRIBUTION SYSTEM AS A RESULT OF COMPLETE LOSS IN NORMAL SYSTEM PRESSURE.

BACTERIOLOGICAL SAMPLES TAKEN ON MONDAY, OCTOBER 31, 2016 WERE FOUND TO BE "SAFE" AND A SATISFACTORY DISINFECTANT LEVEL HAS BEEN ESTABLISHED THROUGHOUT THE DISTRIBUTION SYSTEM. THE WATER IS THEREFORE CONSIDERED "SAFE" FOR HUMAN CONSUMPTION AND THE "BOIL WATER" NOTICE IS HEREBY LIFTED.

THE BOIL WATER ORDER WAS DUE TO PRESSURE LOSS

SYSTEM PERSONNEL NOTIFIED: BRANDON WALRAVEN BY: JASON GILKEY ON: 10/31/2016 1:00:49 PM  
SANITARIAN NOTIFIED: BANKS, DUSTIN|GREENWOOD, MATTHEW|STEVEN TOMPKINS BY: JASON GILKEY  
ON: 10/31/2016 1:00:50 PM