



# Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

**Governor Asa Hutchinson**

**Nathaniel Smith, MD, MPH, Director and State Health Officer**

Engineering Section, Slot 37  
[www.Healthy.Arkansas.gov/eng/](http://www.Healthy.Arkansas.gov/eng/)

Ph 501-661-2623 Fax 501-661-2032  
After Hours Emergency 501-661-2136

Friday, December 02, 2016

LEMLEY, AMBER  
LITTLE RIVER CO RDA  
P. O. BOX 527  
FOREMAN, AR 71836

RE: BOIL WATER NOTICE LIFT  
LITTLE RIVER CO RDA - PWS ID # 787  
LITTLE RIVER COUNTY

Dear Manager:

The Department of Health has released the “Boil Water” Notice confirmed on 11/30/2016 10:42:50 AM by Brandon Walravan for the all Little River RDA connections north of HWY 108.. This order was issued as a precautionary measure because of the possibility that contaminated water may have entered the distribution system as a result of complete loss in normal system pressure.

Bacteriological samples taken on Thursday, December 01, 2016 were found to be free of bacterial contamination and a satisfactory disinfectant level has been established throughout the distribution system. The water is therefore considered “Safe” for human consumption and the “Boil Water” notice is hereby lifted.

Sincerely,

Stephen Youngblood  
District Engineer  
Engineering Section

**LITTLE RIVER CO RDA  
LITTLE RIVER COUNTY**

**PRECAUTIONARY BOIL ORDER NOTICE**

LIFT DATE: FRIDAY, DECEMBER 02, 2016

FOR FURTHER INFORMATION, CONTACT  
STEPHEN YOUNGBLOOD  
DISTRICT ENGINEER  
ENGINEERING SECTION, (501) 661-2623

NEWS ARTICLE

FOR IMMEDIATE RELEASE

THE DEPARTMENT OF HEALTH HAS RELEASED THE “BOIL WATER” NOTICE ISSUED ON 11/30/2016 10:42:50 AM BY BRANDON WALRAVAN FOR THE ALL LITTLE RIVER RDA CONNECTIONS NORTH OF HWY 108.. THIS ORDER WAS ISSUED AS A PRECAUTIONARY MEASURE BECAUSE OF THE POSSIBILITY THAT CONTAMINATED WATER MAY HAVE ENTERED THE DISTRIBUTION SYSTEM AS A RESULT OF COMPLETE LOSS IN NORMAL SYSTEM PRESSURE.

BACTERIOLOGICAL SAMPLES TAKEN ON THURSDAY, DECEMBER 01, 2016 WERE FOUND TO BE “SAFE” AND A SATISFACTORY DISINFECTANT LEVEL HAS BEEN ESTABLISHED THROUGHOUT THE DISTRIBUTION SYSTEM. THE WATER IS THEREFORE CONSIDERED “SAFE” FOR HUMAN CONSUMPTION AND THE “BOIL WATER” NOTICE IS HEREBY LIFTED.

THE BOIL WATER ORDER WAS DUE TO A MAIN BREAK

SYSTEM PERSONNEL NOTIFIED: BRANDON WALRAVEN BY: STEPHEN YOUNGBLOOD  
1:20:50 PM  
SANITARIAN NOTIFIED: BANKS, DUSTIN|GREENWOOD, MATTHEW|STEVEN TOMPKINS  
YOUNGBLOOD ON: 12/2/2016 1:20:51 PM

ON: 12/2/2016

BY: STEPHEN